



बड़ौदा राजस्थान क्षेत्रीय ग्रामीण बैंक
Baroda Rajasthan Kshetriya Gramin Bank
(बैंक ऑफ बड़ौदा द्वारा प्रायोजित) (Sponsored by Bank of Baroda)

दिनांक : 15.06.2021

दिनांक 27.05.2021 को हमारे द्वारा जारी की गई निविदा "Request for Proposal (RFP) For Empanelment of Vendor for Supply, Installation & Commissioning of Online UPS"

में संशोधन :-

1-

क्र. सं.	पेज संख्या / पैरा संख्या / बिन्दु संख्या	पूर्व की शर्तें	संशोधित शर्तें
1	2/Scope of Work	Successful bidder will be empaneled for the period of 3 year.	Successful bidder will be empaneled for the period of 3 year. After satisfactory services of vendor, If bank desires, period can be extended for next one year.
2	10/Technical Specification for UPS	DESCRIPTION 3 KVA/5KVA UPS with Isolation transformer copper input side of ups	DESCRIPTION 3 KVA/5KVA UPS with Isolation transformer Aluminum input side of ups
3	10/Technical Specification for UPS	Redundancy- Redundant capability with optional automatic redundant switch	Point removed/Not Required
4	10/Technical Specification for UPS	Overload Ratings – 105% infinite	Overload Ratings – 110% for 10 Minutes 125% for 60 Sec
5	10/Technical Specification for UPS	Power Factor- more than 0.8 pf for 3KVA and 5 KVA	Power Factor- output power factor 0.8/0.9 pf for 3KVA and 5 KVA
6	10/Technical Specification for UPS	Metering – Output Voltage, Output Current	Metering – Output Voltage, Load level

2-

क्र. सं.	विवरण	पूर्व की शर्तें	संशोधित शर्तें
1	Last date and time for submission	16-06-2021 up to 17.00 Hrs.	22-06-2021 up to 17.00 Hrs.
2	Date and Time of opening Technical Bid	18-06-2021 11.00 Hrs.	24-06-2021 11.00 Hrs.
3	Date and Time of opening Financial Bid	21-06-2021 11.00 Hrs.	25-06-2021 12.00 Hrs.

3- निविदा की अन्य शर्तें यथावत रहेंगी।

महाप्रबन्धक